

CERTIFICATE OF COMPLIANCE

Certificate Number 20120326-R22147
Report Reference R22147, 2012 March 26
Issue Date 2012 March 26

Issued to: Premier Products Inc.
2840 Hwy 165 N
Monroe, LA 71203


This is to certify that representative samples of **Door Frames**

Have been investigated by UL in accordance with the Standard(s) indicated on this Certificate.

Standard(s) for Safety: ANSI A250.13 - 2003
ASTM E330 - 02
ASTM E1886 - 02
ASTM E1996 - 02

Additional Information: See the UL Online Certifications Directory at www.ul.com/database for additional information

Only those products bearing the UL Classification Mark should be considered as being covered by UL's Classification and Follow-Up Service.

The UL Classification Mark includes: UL in a circle; with the word "CLASSIFIED"  (as shown); a control number (may be alphanumeric) assigned by UL; a statement to indicate the extent of UL's evaluation of the product; and the product category name (product identity) as indicated in the appropriate UL Directory.

Look for the UL Classification Mark on the product.

Frames for single swing doors up to 4 ft. x 8 ft. and Standard pairs up to 6 ft. x 7 ft. Maximum Design Load of 85 PSF.

See Classification Card for R22147 for installation specifics.
May be installed in drywall, masonry or structural steel walls.
Also tested to TAS 201, 202, 203.

William R. Carney, Director, North American Certification Programs
UL LLC

Any information and documentation involving UL Mark services are provided on behalf of UL LLC (UL) or any authorized licensee of UL. For questions, please contact a local UL Customer Service Representative at www.ul.com/contactus

